

April 26, 2024

ADDENDUM #1

TO ALL PROSPECTIVE BIDDERS:

SUBJECT: Automatic Temperature Control System Replacement at Oak View Elementary School
(MMB-074-24)

BID OPENING DATE: (ORIGINAL DATE) April 29, 2024, at 10:00 AM

THE SUBJECT INVITATION FOR BID IS AMENDED AS FOLLOWS:

THIS ADDENDUM IS SUPPLEMENTARY TO THE PLANS AND SPECIFICATIONS FOR THE ABOVE SUBJECT REQUIREMENT. ALL CHANGES, ADDITIONS AND DELETIONS SHALL BECOME PART OF THE CONTRACT.

CLARIFICATION: The following is being provided as clarification to the bidders.

Control relays:

Control relays must be installed for all the major equipment, including main plant, RTUs and AHUs. The control relays' contracts shall be wired to the equipment control terminals, and the coil connected to the corresponding physical output of the BAS controller. The control relays shall be installed inside the HVAC equipment and shall have an LED indicator for ON position. Wiring BAS control outputs directly from the controller to the HVAC equipment control terminal or components without utilizing control relays is prohibited.

All other terms and conditions remain unchanged.



Angela C. Mylechraine, Contracts Administrator
Office of Administrative Services

THIS ADDENDUM IS ACKNOWLEDGED AND IS CONSIDERED A PART OF THE SUBJECT INVITATION FOR BID.

SIGNATURE: _____ DATE: _____

NAME OF FIRM: _____

A SIGNED COPY MAY BE RETURNED PRIOR TO BID OPENING OR MAY ACCOMPANY YOUR BID.